

**Office of Civil Surgeon, Kurukshetra**

No. GH/2024/ 1606

Date: 16/7/24

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team headed by MPHS(M), O/o Civil Surgeon, Kurukshetra from Health Department inspected the building of Sahara International School, Village Ban, Ladwa District Kurukshetra on 16-07-2024 and on the basis of water test report bearing No. 982 dated 02-07-2024 of PHED lab KKR certified that the Sahara International School, Village Ban, Ladwa District Kurukshetra has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt. This certificate is valid till 15-07-2025.

Signature with seal : .....  
Name : .....  
Designation : .....  
Name & Address of the office/Department:  
O/o Civil Surgeon, Kurukshetra

To  
Principal,  
Sahara International School, Village Ban,  
Ladwa District Kurukshetra

Sahara International School  
Principal

Sahara International School  
President/Secretary/Cashier





Govt. of Haryana  
Public Health Engineering Department, Water Testing Laboratory, Kurukshetra  
Email id: chemist.kktra@gmail.com

**Test Report**

URL No. : TC456023000000535 F	Sample Collected on Date : 28/06/2024
Test Report No.: KKR/02322/6/2024	Sample Received on Date : 28/06/2024
Sender : Principal, Sahara international school, LADWA	Sample Location :- Sahara international school, LADWA
Customer Reference No. : 0	Sample Quantity : 1 Ltr.
Sample Description : Water	Date of Analysis Started : 28/06/2024
Sample Type : Physico-Chemical Analysis	Date of Analysis Completed : 02/07/2024
Memo No. : 983 Date: 02/07/2024	Date of issue : 02/07/2024

S.No	Parameter	Protocol used	Result	IS:10500:2012(Second revision)		Unit
				Acceptable Limit	Permissible limit in the absence of alternate source	
1	Colour	IS 3025(Part-4): 1983 (RA 2017)	<05	5	15	Hazen
2	Odour	IS 3025(Part-5): 1984 (RA 2018)	Agreeable	Agreeable	Agreeable	-
3	Taste	IS 3025(Part-8): 1984 (RA 2017)	Agreeable	Agreeable	Agreeable	-
4	Total Dissolve Solids	IS 3025(Part-16): 1984 (RA 2017)/ APHA2540C	478	500	2000	mg/L
5	Total Hardness	IS 3025(Part-21): 2009 (RA 2019)/ APHA2340C	325.21	200	600	mg/L
6	Calcium (as Ca)	IS 3025(Part-40): 1991 (RA 2019)/ APHA3500-Ca B	73.20	75	200	mg/L
7	Magnesium (as Mg)	IS 3025(Part-46): 1994 (RA 2019)/ APHA3500-Mg B	33.94	30	100	mg/L
8	Total Alkalinity	IS 3025(Part-23): 1986 (RA 2019)/ APHA2320 B	450.45	200	600	mg/L
9	Chloride (as Cl)	IS 3025(Part-32): 1988 (RA 2019)/ APHA4500-Cl B	19.14	250	1000	mg/L
10	Fluoride (as F)	APHA4500-F C	0.159	1.0	1.5	mg/L
11	PH	IS 3025(Part-11): 1983 (RA 2022)/ APHA4500-H B	7.19	6.5 to 8.5	No Relaxation	-
12	Turbidity	IS 3025(Part-10): 1998 (RA 2022)/ APHA2130 B	BDL	1	5	NTU

**Notes:**

- 1 The results given above are related to the sample as received and tested in PHED Lab, Kurukshetra. Reliability of sample lies with the sender.
- 2 The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- 3 The test report can't be used for any publicity or any legal purpose.
- 4 The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

CHEMIST (Nisha Saini)  
Authorized Signatory/Chemist  
Public Health Engg. Department  
Kurukshetra  
Water Testing Lab, Kurukshetra

Sahara International School

Principal

Sahara International School

President/Secretary/Cashier





**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**DISTRICT WATER TESTING LABORATORY, KURUKSHETRA**

Website :- <https://phedharyana.gov.in/>

Memo No:- 982

Date:- 02/07/2024

**Subject : Bacteriological Examination Report of Water Sample**

Sample ID: KKR/02321/6/2024	<b>Sample Details</b>	<b>Date &amp; Time</b>
Sample Classification: Private	Collected By	Principal Saha...,9034944444
Sender: SAHARA INTERNATIONAL SCHOOL33204	Collection Date	28/06/2024 at 15:06
Location :- , Ladwa	Received at lab	28/06/2024 at 15:26
Latitude :- 77.073716 Longitude :- 30.000068	Tested at Lab	02/07/2024


Test Result (As Per BIS 10500 :2012)				
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.

Water Sample has been found **"CONFORMING"** to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found **"POTABLE"**



  
NISHA SAINI,CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
DISTRICT WATER TESTING  
LABORATORY KURUKSHETRA  
email:-chemist.kkra@phedharyana.gov.in

—End of Report—

Sahara International School  
  
Principal

Sahara International School  
  
President/Secretary/Cashier